



# Transformer Oil Testing (TOT) Digital Platforms

2026


Moving Forward

Leading the way for sustainable solutions



# Technical Report


- VPS Power have electrical oil and transformer experts allowing for bespoke diagnostic comments.
- The condition of the oil or equipment is shown by an easy-to-understand colour coding system.
- Historical samples are used for trending purposes to help predict a fault and prevent potential outages
- VPS Power Reports include:
  - Sample and transformer details
  - Fluid, gas, insulating paper, environmental & investigative results
  - Trends using previous samples
  - Comments from technical experts



# Reports

## Report Summary with Ratings:

This feature provides visibility of the status of the report, when you receive the email with the pdf reports.



**TRANSFORMER OIL TEST REPORT**

Customer: ABC

Sample Details		Asset Details		Rating
Sample Number	MCR24P33896	Serial Number	Y17820	11.5/16.5/23 MVA
Batch Number	B41T5038	Unit Description	Primary Transformer 3	33/11.5 kV
Date of Receipt	27-Dec-2024	Job No	U1326924	Oil Quantity 1860 Gallons
Report Date	03-Jan-2025			Manufacturer Yorkshire Electric
				Year of Manufacture 1969

	Current Sample	Historical	
Sample Number	MCR24P33896	MCR23P00094	MCR22P24478
Sampling Point	Bottom Main Tank	Bottom Main Tank	Bottom Main Tank
Sampling Date	10-Dec-2024	06-Dec-2022	17-Oct-2022
Oil Temperature (°C)	8.0	12.0	25.0

Test Results	Unit	Method	46.50	30.70	43.80	
Resistivity (90°C)	GDm	IEC 60247				IEC 60422 - 2024 - Mineral Oils in Service, Category C
Dielectric Factor (90°C)						0.2 Min
Acidity	mg KOH/g	IEC 62021-2	0.00738	0.0107	0.0076	0.5 Max
Breakdown Voltage	kV	IEC 60156	19	64	42	30 Min
Water Content	mg/kg	IEC 60814 M	112	15	22	40 Max
Colour		LP 7300	Light Amber	Light amber	Light amber	Not dark
Appearance		LP 7300	Free Water	Sediment	Sediment	Clear
Fibres		LP 7300	High >50/l	Medium 15-50/l	Low <15/l	-
Furans (2-furfural)	mg/kg	IEC 61198-A	0.36	0.35	0.41	-
Estimated DP		Chendong	558	562	542	250 Min
Polychlorinated Biphenyls (PCB)	mg/kg	IEC 61619	7	9	7	50 Max

Dissolved Gas Analysis				DGA Interpretation IEC 60599		
Hydrogen	µl/l	IEC 60567	< 0.5	1.65	2.49	-
Methane	µl/l	IEC 60567	1.34	2.62	2.51	-
Ethane	µl/l	IEC 60567	0.4	1.20	1.32	-
Ethylene	µl/l	IEC 60567	1.25	3.54	3.67	-
Acetylene	µl/l	IEC 60567	< 0.01	< 0.01	0.04	-
Carbon Monoxide	µl/l	IEC 60567	< 25	60	60	-
Carbon Dioxide	µl/l	IEC 60567	1858	5395	5852	-
Oxygen	µl/l	IEC 60567	30516	30224	31428	-
Nitrogen	µl/l	IEC 60567	63202	61481	66247	-
TDCS	µl/l	IEC 60567	24.99	68.93	70.47	-
Total Gas	µl/l	IEC 60567	95601	97168	103597	-

**Comments**

**Hydrocarbon Gases** There is no indication of abnormal gas generation.

**Carbon Oxide Gases** Consistent with normal ageing of insulating fluid and cellulose insulation.

**Insulating Medium** Resistivity, dielectric factor and acidity are good according to IEC 60422. However, breakdown voltage and water content are poor. The mechanical strength of the paper insulation is indicated by the estimated degree of polymerisation (DP). New paper starts with a DP of 1000 or more, and as the paper starts to age, or is damaged by poor fluid management or operational events, so the DP reduces. Estimated DP indicates the cellulose insulation is reduced to approximately 60% mechanical strength, with minimal to mild ageing. PCB contamination is below the UK regulation of 50 mg/kg max.

**Recommendation** The sample contained free water and may not be representative. A fresh sample should be taken to confirm the fluid condition. Ensure the sampling valve is cleaned and 1-2 litres of fluid flushed to waste before sampling.

**Next Sampling Date** Following the above recommendation.

Approved by: R. Burgess  
[Evan.Burgess@vps.com](mailto:Evan.Burgess@vps.com)

Rating

**ACTION**

This report may not be reproduced, except in full, without the explicit permission of the laboratory. Results apply to the sample as received. Whilst every care is taken in preparation of this report, the laboratory cannot be held responsible for any information provided by the customer. Precision parameters apply in the determination of the results in this report. Reference to part(s) of this report which may lead to misinterpretation is prohibited. This report is issued under the Veritas Petroleum Services General Terms and Conditions.

Page 1 of 1

# Technical Reports

Pass

**UPS POWER TRANSFORMER OIL TEST REPORT**

Customer: ABC

Sample Details	Asset Details	Rating
Sample Number: MCR24P2328	Serial Number: Y18535	Rating: 7.5/15 MVA
Batch Number: S4T1210	Unit Description: Transformer 1	Voltage: 11/11.5 kV
Date of Receipt: 18-Oct-2024	Order No: 157189	Oil Quantity: 1560 Gallons
Report Date: 19-Oct-2024	Job No: 110676	Manufacturer: Yorkshire Electric
		Year of Manufacture: 1971

**Test Results**

Unit	Method	EC 60422: 2024 - Mineral Oils in Service, Category C
Acidity	mg KOH/g	0.69
Breakdown Voltage	kV	72
Water Content	mg/kg	18
Colour	LP 7300	Light Amber
Appearance	LP 7300	Sediment
Fibres	LP 7300	Low <15/1

**Disolved Gas Analysis**

Gas	Unit	EC 60567						
Hydrogen	µl/l	5.37	-	-	-	-	-	-
Methane	µl/l	4.55	-	-	-	-	-	-
Ethane	µl/l	3.81	-	-	-	-	-	-
Ethylene	µl/l	5.56	-	-	-	-	-	-
Acetylene	µl/l	<0.01	-	-	-	-	-	-
Carbon Monoxide	µl/l	327	-	-	-	-	-	-
Carbon Dioxide	µl/l	1448	-	-	-	-	-	-
Oxygen	µl/l	30323	-	-	-	-	-	-
Nitrogen	µl/l	83024	-	-	-	-	-	-
TDS	µl/l	343.69	-	-	-	-	-	-
Total Gas	µl/l	84939	-	-	-	-	-	-

**Comments**

Hydrocarbon Gases: No indication of abnormal gas generation.

Carbon Oxide Gases: Consistent with normal ageing of insulating fluid and cellulose insulation.

Insulating Medium: Acidity, breakdown voltage and water content are good according to EC 60422. Sample represents transformer / insulating fluid in satisfactory condition for continued service.

Next Sampling Date: 03-Oct-2025

Approved by: A. Jenkins  
Address: a.jenkins@powerins.com

Rating: **PASS**

This report may not be reproduced, except in full, without the explicit permission of the laboratory. Results apply to the sample as received. Where every care is taken in preparation of this report, the laboratory cannot be held responsible for any information provided by the customer. Precision parameters apply in the determination of the results in this report. Reference to parts of this report which have not been reproduced is prohibited. This report is issued under the British Petroleum Services General Terms and Conditions.

Caution

**UPS POWER TRANSFORMER OIL TEST REPORT**

Customer: ABC

Sample Details	Asset Details	Rating
Sample Number: MCR24P2392	Serial Number: 11234	Rating: 1250 MVA
Batch Number: S4T1210	Unit Description: Transformer 4	Voltage: 11.5/18.411 kV
Date of Receipt: 18-Oct-2024	Order No: 701214	Oil Quantity: 320 Litres
Report Date: 18-Oct-2024	Job No: 13251454	Manufacturer: Windsor
		Year of Manufacture: 1993

**Test Results**

Unit	Method	EC 60422: 2024 - Mineral Oils in Service, Category C
Acidity	mg KOH/g	0.06
Breakdown Voltage	kV	74
Water Content	mg/kg	18
Colour	LP 7300	Light Amber
Appearance	LP 7300	Clear & Bright
Fibres	LP 7300	Low <15/1
Ferrous (2-ferrous)	mg/kg	0.65
Estimated DP	Chendong	493

**Disolved Gas Analysis**

Gas	Unit	EC 60567						
Hydrogen	µl/l	<0.5	1.41	0.75	-	-	-	-
Methane	µl/l	7.88	19.25	1.36	-	-	-	-
Ethane	µl/l	13.15	16.57	1.54	-	-	-	-
Ethylene	µl/l	89.11	89.53	1.47	-	-	-	-
Acetylene	µl/l	0.85	0.75	<0.01	-	-	-	-
Carbon Monoxide	µl/l	<25	<25	<25	-	-	-	-
Carbon Dioxide	µl/l	582	628	906	-	-	-	-
Oxygen	µl/l	32629	27651	24151	-	-	-	-
Nitrogen	µl/l	69673	60649	62321	-	-	-	-
TDS	µl/l	136.14	136.47	27.84	-	-	-	-
Total Gas	µl/l	35189	89102	117616	-	-	-	-

**Comments**

Hydrocarbon Gases: A high temperature thermal fault (> 300°C) is confirmed.

Carbon Oxide Gases: Consistent with normal ageing of insulating fluid and cellulose insulation.

Insulating Medium: Acidity, breakdown voltage and water content are good according to EC 60422. The mechanical strength of the paper insulation is indicated by the estimated degree of polymerisation (DP). New paper starts with a DP of 3000 or more, and as the paper starts to age, or is damaged by poor fluid management or operational events, as the DP reduces. Estimated DP indicates the cellulose insulation is reduced to approximately 50% mechanical strength, showing some deterioration but still well away from the colour condition.

Recommendation: Re-sample in THREE MONTHS to monitor the fault and ensure the gases remain stable. Normal operation should be continued to this point.

Next Sampling Date: 03-Mar-2025

Approved by: A. Jenkins  
Address: a.jenkins@powerins.com

Rating: **CAUTION**

This report may not be reproduced, except in full, without the explicit permission of the laboratory. Results apply to the sample as received. Where every care is taken in preparation of this report, the laboratory cannot be held responsible for any information provided by the customer. Precision parameters apply in the determination of the results in this report. Reference to parts of this report which have not been reproduced is prohibited. This report is issued under the British Petroleum Services General Terms and Conditions.

Action

**UPS POWER TRANSFORMER OIL TEST REPORT**

Customer: ABC

Sample Details	Asset Details	Rating
Sample Number: MCR24P2396	Serial Number: 117620	Rating: 11.5/18.411 MVA
Batch Number: S4T1210	Unit Description: Primary Transformer 3	Voltage: 33/11.5 kV
Date of Receipt: 17-Oct-2024	Order No: 13333824	Oil Quantity: 2380 Gallons
Report Date: 03-Jan-2025	Job No:	Manufacturer: Yorkshire Electric
		Year of Manufacture: 1967

**Test Results**

Unit	Method	EC 60422: 2024 - Mineral Oils in Service, Category C
Acidity	mg KOH/g	46.50
Breakdown Voltage	kV	30.73
Water Content	mg/kg	30.73
Colour	LP 7300	Light Amber
Appearance	LP 7300	Fine Water
Fibres	LP 7300	High >50/1
Ferrous (2-ferrous)	mg/kg	0.56
Estimated DP	Chendong	554
Polychlorinated Biphenyls (PCB)	mg/kg	EC 61619

**Disolved Gas Analysis**

Gas	Unit	EC 60567						
Hydrogen	µl/l	<0.5	1.65	2.49	-	-	-	-
Methane	µl/l	3.88	2.62	2.55	-	-	-	-
Ethane	µl/l	0.97	1.29	1.32	-	-	-	-
Ethylene	µl/l	1.95	3.51	3.04	-	-	-	-
Acetylene	µl/l	<0.01	<0.01	0.04	-	-	-	-
Carbon Monoxide	µl/l	<25	50	60	-	-	-	-
Carbon Dioxide	µl/l	1808	1993	1822	-	-	-	-
Oxygen	µl/l	30918	30234	31428	-	-	-	-
Nitrogen	µl/l	83002	84481	86247	-	-	-	-
TDS	µl/l	24.99	68.89	79.47	-	-	-	-
Total Gas	µl/l	93665	97188	103957	-	-	-	-

**Comments**

Hydrocarbon Gases: There is no indication of abnormal gas generation.

Carbon Oxide Gases: Consistent with normal ageing of insulating fluid and cellulose insulation.

Insulating Medium: Relatively, acidity factor and water content are good according to EC 60422. However, breakdown voltage and water content are poor. The mechanical strength of the paper insulation is indicated by the estimated degree of polymerisation (DP). New paper starts with a DP of 3000 or more, and as the paper starts to age, or is damaged by poor fluid management or operational events, as the DP reduces. Estimated DP indicates the cellulose insulation is reduced to approximately 50% mechanical strength, with minimal to mild aging. PCB contamination is below the UK regulation of 50 mg/kg max.

Recommendation: The sample contained fine water and may not be representative. A fresh sample should be taken to confirm the fluid condition. Ensure the sampling valve is cleaned and 1-2 litres of fluid flushed to waste before sampling.

Next Sampling Date: Following the above recommendation.

Approved by: R. Burgess  
Address: r.burgess@powerins.com

Rating: **ACTION**

This report may not be reproduced, except in full, without the explicit permission of the laboratory. Results apply to the sample as received. Where every care is taken in preparation of this report, the laboratory cannot be held responsible for any information provided by the customer. Precision parameters apply in the determination of the results in this report. Reference to parts of this report which have not been reproduced is prohibited. This report is issued under the British Petroleum Services General Terms and Conditions.

**INTERNATIONAL STANDARD**  
NORME INTERNATIONALE

Mineral insulating oils in electrical equipment – Supervision and maintenance guidance  
Huiles minérales isolantes dans les matériels électriques – Lignes directrices pour la maintenance et la surveillance

**INTERNATIONAL STANDARD**  
NORME INTERNATIONALE



Esters organiques de synthèse à usages électriques – Guide de maintenance des esters pour transformateurs dans les matériels  
Synthetic organic esters for electrical purposes – Guide for maintenance of transformer esters in equipment

**INTERNATIONAL STANDARD**  
NORME INTERNATIONALE

Natural esters – Guidelines for maintenance and use in electrical equipment  
Esters naturels – Lignes directrices pour la maintenance et l'utilisation dans les matériels électriques

ISO 17025 accredited reports issued to the most up-to-date international standards by the UK's most experienced Transformer Diagnostics Advisors. Reports are supported by a dedicated Technical hotline.

# Advanced Technical Reports



Advanced technical reports provide a more detailed insight into your assets health displaying thermal and electrical fault models and trending of test data.


# MyTransformers:

VPS' latest business intelligence tool, focused on transformer oil condition monitoring and asset integrity.

Summary dashboard



Grouped test result analysis




Detailed test result analysis



Asset rate of change




All test result data



- ▶ Custom MyTransformers dashboard.
- ▶ Monitor asset and equipment health.
- ▶ Roger ratios and Duval triangle calculations.

# Customer Portal



## DASHBOARD

Summarize sample submissions and report rating statuses.



## REPORTS

Access PDFs and export data to Excel effortlessly.



## TRENDS

Visualize current and historical results with interactive line graphs.



## ASSETS

Review existing assets, set sampling frequencies, and activate email notifications.



## SCHEDULER

Track upcoming/overdue sampling and generate electronic labels.





## SAMPLING

Arrange seamless sample collection and tracking.

# Mobile App

Review sample and report rating status, upcoming/overdue assets for sampling, current and historical results, and register/create electronic labels for samples with QR code technology.




# MyTransformers

How many reports resulted in a warning?  
# reports that tested pass, caution or fail.




warning = caution + fail.

Which test parameters failed to operate within limit?  
The top 5 test parameters that were flagged as off-spec.




if there is an 'others' bar, click to view the next 5.


Where are my assets located?



Gas quality




Fluid quality



Insulating paper quality



Environmental assessment



Set-up bookmarks to monitor key assets' integrity and transformer oil performance.

Drill-down from a company level overview to asset level quality statistics.

User-friendly dashboarding feature provides asset managers with immediate insights on asset integrity.

Gain access to all your transformer oil testing data with VPS within a few clicks.

Forensic workflow feature enables users to immediately identify anomalies and outliers in asset integrity and performance.



# Contact

---

**James Robinson**

Business Manager - VPS Power  
[James.Robinson@vpsveritas.com](mailto:James.Robinson@vpsveritas.com)

**Naheed Umarji**

Sales Manager - VPS Power  
[Naheed.Umarji@vpsveritas.com](mailto:Naheed.Umarji@vpsveritas.com)

[vpsveritas.com](http://vpsveritas.com)

**Moving Forward**

Leading the way for sustainable solutions

